



Certificate number: 2411704 (1)

Issued 04/11/2024

Expires 31/12/2025

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

WILO (U.K.) Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

WILO (U.K.) Ltd
2nd Avenue
Centrum 100
Burton-upon-Trent
Staffordshire
DE14 2WJ
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2411704

The following products belong to this certificate

PRODUCT DESCRIPTION Range of inline circulating pumps with bronze bodies, plastic impeller and EPDM rubber seals. ATS3 – Without Production Surveillance.
MODEL(S) SB 30 – 1 ½" SB5 – 1" SB 30 G – 1 ¼" SB 60 – 1 ½"
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 10 Bar & maximum operating temperature 100°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground use only.
MARKING WILO, PN, Serial No, Date of Manufacture (YYWW) and other technical information.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes